

FIRE SAFETY CERTIFICATE

No.

Dated: 05-06-2024

Certified that the MRA DAV PUBLIC SCHOOL SOLAN (name of the building or premises) at MRA DAV PUBLIC SCHOOL BYPASS SOLAN H.P. (address) comprised of 6.1.3 floor (upper floors) owned/ occupied by MRA DAV PUBLIC SCHOOL BYPASS SOLAN (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 13.10.2022 (date of inspection) in the presence of PRINCIPAL (MRA DAV) (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes (XI XII) With effect from 27.10.2022 for a period of 26.10.2024 (2) year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 05-06-2024 (date of issue) at H.S. Solan (place) by

*Strike out whichever is not applicable.

Signature with Seal:

Kamaljeet Singh
Sub Fire Officer,
Fire Station, Solan (H.P.)

Name

: Kamaljeet Singh

Designation

: SFO

Name & Address of Department/ Office: Fire Station Solan
Near the ground, Rajgash
Road Solan H.P.

To PRINCIPAL

MRA DAV PUBLIC SCHOOL SOLAN

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to not proper care and maintenance of fire safety installations
(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Single Window Clearance System

Directorate of Industries(DOI)
Govt. of Himachal Pradesh

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2

NO OBJECTION CERTIFICATE

TO WHOM IT MAY CONCERN


That the premises of **MRA DAV PUBLIC SCHOOL, BY PASS SOLAN HP** was inspected on 2022-10-5 with reference to his application No. App/09/15/22/8/164 dated 2022-09-15 12:08:22 by the incharge Fire Station FS Solan with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for two years w.e.f. 27/10/2022 to 26/10/2024 subject to fulfilment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire services.
4. Good House keeping must be maintained within the premises.

हिमाचल प्रदेश सरकार

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function where temporary structures and Pandals are to be erected.


[Digitally Signed 27-10-2022 15:49:35]
Chief Fire Officer.
Himachal Pradesh Shimla-2

Place: Shimla
Dated: 2022-10-27